



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7770-0328:0140
CATEGORY:	7770 - VALVES/SWITCHES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Model VSRF-EX , 2" to 10", paddle type, open or closed circuit, water flow indicator. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	10A, 125, 250 VAC; 2.5A, 30 VDC Max. 450 psi up to 8" size, max. 250 psi for 10" size
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number and UL label.
APPROVAL:	Listed as waterflow alarm switches for use with fire sprinkler systems. For vertical or horizontal installation in wet pipe sprinkler systems to produce alarm signals when circuited with a separately listed compatible fire alarm control unit. Suitable for use in hazardous locations, Class I, Group C and D; Class II, Group E, F and G.
NOTES:	

*Rev 6-20-2002



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division