



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7165-0328:0155												
<b>PARENT LISTING No.:</b>													
<b>CATEGORY:</b>	-												
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com												
<b>DESIGN:</b>	<p>Model PFC-5002, PFC-5004 and PFC-5004E fire alarm control units. Non-coded; automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory service. System components:</p> <table border="0"> <tr> <td>PFC-5002, -5004, -5004E</td> <td>Main Fire Alarm Assembly</td> </tr> <tr> <td>DM-204</td> <td>Initiating &amp; NAC Zones</td> </tr> <tr> <td>RM-204, RM-208</td> <td>Relay Module</td> </tr> <tr> <td>PR-100</td> <td>Polarity reversal &amp; City Tie</td> </tr> <tr> <td>DACT-100</td> <td>DACT</td> </tr> <tr> <td>BB-815, BB-816</td> <td>Enclosure</td> </tr> </table>	PFC-5002, -5004, -5004E	Main Fire Alarm Assembly	DM-204	Initiating & NAC Zones	RM-204, RM-208	Relay Module	PR-100	Polarity reversal & City Tie	DACT-100	DACT	BB-815, BB-816	Enclosure
PFC-5002, -5004, -5004E	Main Fire Alarm Assembly												
DM-204	Initiating & NAC Zones												
RM-204, RM-208	Relay Module												
PR-100	Polarity reversal & City Tie												
DACT-100	DACT												
BB-815, BB-816	Enclosure												
<b>RATING:</b>													
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.												
<b>MARKING:</b>	Listee's name, model number, electrical rating and UL label.												
<b>APPROVAL:</b>	<p>Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.</p> <p>This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation instructions Manual for details.</p>												



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

**NOTES:**

For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart period shall not exceed 30.0 seconds.

This control unit meets the requirements of UL-864, 8th Edition.



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/03/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo** , Program Coordinator  
Fire Engineering & Investigations Division