



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7320-0328:0206								
PARENT LISTING No.:	7320-0569:0141								
CATEGORY:	7320 - SPEAKERS								
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com								
DESIGN:	Models FASPKR speaker, CSPKSTR-24-15/75WLP speaker strobes and GBLP backbox. Model FASPKR followed by R (red) or W (white). Model CSPKSTR, followed by A (amber), B (blue), G (green), R (red) indicating, followed by 24-15/75, may be followed by -A (alert) , -P (plain), then followed by W (wall) and followed by R (red) or W (white). Suffix WLP indicates wall mount and low profile design. All models are intended for use with Model GBLP backbox for outdoor applications. Strobe is intended for non-fire applications. Refer to listee's data sheet for additional detailed product description and operational considerations.								
RATING:	<table border="0"> <tr> <td>Speaker</td> <td>25 Vrms and 70.7 Vrms</td> </tr> <tr> <td>Strobe</td> <td>24 VDC</td> </tr> <tr> <td>Flash Rate</td> <td>60 flashes per minute</td> </tr> <tr> <td>Candela</td> <td>15/75</td> </tr> </table>	Speaker	25 Vrms and 70.7 Vrms	Strobe	24 VDC	Flash Rate	60 flashes per minute	Candela	15/75
Speaker	25 Vrms and 70.7 Vrms								
Strobe	24 VDC								
Flash Rate	60 flashes per minute								
Candela	15/75								
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.								
MARKING:	Listee's name, model number, ratings, and UL label.								
APPROVAL:	<p>Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Model CSPKSTR-24-15/75WLP is NOT suitable for the fire alarm notification for the hearing impaired applications. For indoor and outdoor applications. Refer to manufacturer's Installation Manual for details.</p> <p>These devices do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal.</p>								



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

NOTES:

08-05-13 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/03/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong** , Program Coordinator
Fire Engineering & Investigations Division