



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7135-0328:0210
PARENT LISTING No.:	7135-0569:0135
CATEGORY:	7135 - AUDIBLE DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Model CHS-24A, CHS-24B, CHS-24G and CHS-24R horn/strobe lights. Units employ a strobe flash tube and electronic trigger circuit mounted on a printed wiring board with color lens. Unit is intended for indoor or outdoor use when mounted on the wall only. When used outdoors either Model WPBB weatherproof enclosure or Model WPLPBB low profile weatherproof enclosure must be employed. Unit is for private mode signaling use only. Refer to listee's data sheet for additional product description and operational considerations.
RATING:	Electrical: 16 - 33 VDC Candela: 15cd, 30cd, 60cd, 75cd and 110cd Selectable
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical ratings and UL label.
APPROVAL:	Listed as horn/strobes for use with separately listed compatible fire alarm control units. Not approved for hearing impaired applications.
NOTES:	

07-24-13 gt





**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/03/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division