



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	6912-0328:0220
PARENT LISTING No.:	6912-1446:0101
CATEGORY:	6912 - VOICE COMMUNICATION ACCESSORIES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Model PVX-4Z zone splitter.. The unit is intended to be used in conjunction with a listee's separately listed Model PVX-25, PVX-50, PVX-100, PVX-150 and PVX-200 audio adjunct system (CSFM Listing No. 6911-0328:0219). Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	Input: 24-28 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as a voice communication/audio adjunct system accessories.
NOTES:	

08-06-13 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/03/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong** , Program Coordinator
Fire Engineering & Investigations Division