



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	6911-0328:0221
PARENT LISTING No.:	6911-1446:0103
CATEGORY:	6911 - VOICE COMMUNICATION SYSTEMS CONTROL UNITS
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	<p>Models *PVC-MP and *PVC-DP audio adjunct/voice evacuation systems. The *PVC-MP is the master panel in the system while the *PVC-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:</p> <p>PWR-2A; Power Supply</p> <p>MFP Master; Fire Phone Card</p> <p>DCC ;Data Communication Control Card</p> <p>ASC; Audio System Control Card</p> <p>SSC; Switch Scan Card</p> <p>MMC; Microphone Master Control Card</p> <p>IOI; Input/Output Card</p> <p>SLC; Switch and LED Card</p> <p>MFH; Master Fire Phone Handset Card</p> <p>MBR; Motherboard Card</p> <p>AMI; Audio Module Interface Card</p> <p>FPI; Motherboard/Relay Card</p> <p>PVX's Models PVX-25, -25E, -50, -50E, -100 or -100E; Audio Adjunct Systems</p>
RATING:	120 VAC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as voice communication/evacuation/relocation/paging system for use separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

Revision 10-26-16
dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/03/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong** , Program Coordinator
Fire Engineering & Investigations Division