



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7135-0328:0508
<b>PARENT LISTING No.:</b>	7135-0569:0148
<b>CATEGORY:</b>	7135 - AUDIBLE DEVICES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
<b>DESIGN:</b>	Models LFHS-15, LFHS-110 and LFHS-177 low frequency horn/strobes. Horn/strobes models may be followed by -W or -R (white or red). Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	16-33 Vdc/VFWR  Model LFHS-15 15 candela fixed  Model LFHS-110 110 candela fixed  Model LFHS-177 177 candela fixed
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed low frequency horn/strobes when used with a separately listed electrically compatible fire alarm control unit. Horn/strobe models for wall mount only. All models are for indoor use only. These units can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to listee's Installation Instructions Manual for details.
<b>NOTES:</b>	

08-30-17 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 07/03/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong** , Program Coordinator  
Fire Engineering & Investigations Division