



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0520
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Model NCE-1000 Ethernet Network Card and Model NCF-1000 Fiber Network Card. Units provide networking capability of compatible fire alarm panels using ethernet or fiber optic cable. Intended for indoor dry locations. Refer to listee's printed data sheet for additional detailed product description and operational considerations.
RATING:	24 Vdc Nominal
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, installation environment (indoor dry), and UL label.
APPROVAL:	Listed as control unit accessories for use with listee's separately listed compatible fire alarm control panels. Compatible Fire Alarm Control Panels: Models IPA-60, IPA-100, and IPA-4000 (CSFM Listing No. 7165-0328:0500) Models AFC-50, AFC-100, AFC-1000, and ARC-100 (CSFM Listing No. 7165-0328:0509) Model PFC-4064 (CSFM Listing No. 7165-0328:0511) Refer to listee's Installation Instruction Manual for details.
NOTES:	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

11-24-20 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division