

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7170-0328:0532
CATEGORY:	7170 - CONTROL UNIT (HIGH-RISE)
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Models IPA-4000V and AFC-1000V Fire Alarm Control Units. The units form an interconnected fire alarm control unit with audio system. The system contains a headend panel (IPA-4000V and AFC-1000V) where a microphone is used to capture the user's voice. The microphone is connected to the panel where it is digitized and transmitted via IP packets to the remote amplifier panels. The digital representation of the audio is then converted back to analog line level output by the amplifiers.
	Accessories: Model LOC-1000 - Local Operator Console
	Fire Alarm Equipment: Model FFT-1000 - Fire Fighter Telephone Panel
	Subassembly:
	Model VM-1000 - Voice Module
	Model FFT-EXP - Fire Fighter Phone Expander Module
	Model SB-8 - Switch Board (8) Programmable Interface
	Model SB-24 - Switch Board (24) Programmable Interface
	Model FSB-8 - Fire Fighter Switch Board (8) Programmable Interface
	Model FSB-24 - Fire Fighter Switch Board (24) Programmable Interface
	Model 70V-1000 - Voltage Booster
	Model BUA-1000 - Backup Amplifier
	Models SCA-2525, SCA-2570, SCA-5025, SCA-5070, and SCA-10070 - Addressable Single Channel Amplifiers
	Models DCA-5025 and DCA-10025 - Addressable Dual Channel Amplifiers



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

NOTES:	
APPROVAL:	Listed as fire alarm control units for releasing, smoke control, and in-building mass notification when used with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details. *Models complies with the applicable requirements in UL 864, 10th Edition.
MARKING:	Listee's name, model number, electrical rating, and UL label.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
	24 VDC, 55 Ah
	Secondary Operating Supply:
	240 VAC, 50/60 Hz, 3 A
	120 VAC, 50/60 Hz, 5 A
	Primary Operating Supply:
RATING:	Models IPA-4000V and AFC-1000V:
	Refer to listee's data sheet for additional detailed product description and operational considerations.
	The units employ the following features: alarm verification, supports standard 2-wire smoke detectors, positive alarm sequence, cross zone operation, counting zone operation, detector sensitivity, smoke control (IPA only), mass notification, supports addressable devices, field programming, drift compensation, remote annunciator outputs carbon monoxide alarms, and 520 Hz low frequency.
	*Model SCA-5070INT - Addressable Single Channel Amplifier

*Revision 9-6-23 VWW



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024 Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator Fire Engineering & Investigations Division