



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7165-0328:0535
CATEGORY:	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

<p>DESIGN:</p>	<p>Model PFC-4410G3 Control Unit.</p> <p>Accessories: Model RA-4410G3 Remote Annunciator and Model LED-4410G3 LED Annunciator.</p> <p>Subassemblies: Model RCDS-PM1 Single Switch and RCDS-PM2 Dual Switch Releasing Circuit Disable Switch and Replacement Motherboard/User Interface Assembly, Model 3006744.</p> <p>System Components/Minimum Configuration:</p> <p>PFC-4410G3: Control Unit</p> <p>SSU-00500: Battery Cabinet (Larger than 18 Ah batteries)</p> <p>PFC-TW: White Bezel for Semi-Flush mounting</p> <p>PFC-TR: Red Bezel for Semi-Flush mounting</p> <p>CA-4064: Class A Expander</p> <p>PSN-1000: Power Expander</p> <p>LED-4410G3: LED Annunciator</p> <p>RLY-5: Relay Board</p> <p>RA-4410G3: Remote Annunciator</p> <p>IDC-6: Initiating Device Expender</p> <p>CA2Z: Class A Initiating Module</p> <p>3005013: EOLR</p> <p>3005012: EOLD</p> <p>ARM-1: Polarity Reversing Module</p> <p>RCDS-PM1: Releasing circuit Disable</p> <p>RCDS-PM2: Releasing Circuit Disable</p> <p>Refer to listee's printed data sheet for additional detailed product description and operational considerations.</p>	
<p>RATING:</p>	<p>Primary Operating Supply:</p> <p>120-240 Vac, 50/60 Hz, 3.0 A.</p>	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

INSTALLATION:	In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 864, 10th Edition.
NOTES:	

8-23-22 DAL



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division