



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0546
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Models IntelliCom-5GA and IntelliCom-5GV digital alarm communicator cellular/ethernet transmission device.</p> <p>The Models IntelliCom-5GA and IntelliCom-5GV are identical except for the SIM card employed that determines the cellular carrier.</p> <p>The Model IntelliCom-5GA represents AT&T as the cellular carrier.</p> <p>The Model IntelliCom-5GV represents Verizon as the cellular carrier.</p> <p>Refer to listee's data sheet for additional detailed products description and operational considerations.</p>
RATING:	120 VAC; 12 or 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's Name, Model Number, Electrical Rating, and UL Label.
APPROVAL:	Listed as a digital alarm communicator for use with listee's separately listed fire alarm control panels. Refer to listee's Installation Instruction Manual for details. Model complies with the applicable requirements in UL 864 Standard, 10th Edition.
NOTES:	

8-23-23 DAL



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division