

# Releasing Panel for Water and Agent Extinguishing Systems

(All specifications subject to revision.)



Automatic Water Control Valves Compatibility Data						
Using the Following Solenoids	Devices Per Circuit	Water Valve Manufacturers	Water Valve Designation	Size NPT	PFC-4410RC	PFC-4410G3
ASCO Solenoid Valve Model T8210A107 Model R8210A107 Model 8210A107 24VDC	1	Figgie Fire Protection Systems (Formerly ASCOA)	Model D and F	2½", 4", 6"	X	X
		Grinnell Corp.	Grinnell or Gem Model A-4 Grinnell or Gem Model B Grinnell or Gem Model F445 Grinnell or Gem Model F470	4", 6" 2" 2½" 4", 6"	X	X
Parker/Skinner Solenoid Valve Model 73218BN4UNLVN0C111C2 24VDC	1	Central Sprinkler	Model A	6"	X	X
		Reliable Automatic Sprinkler Co. Inc.	Model A Models B, BX and DDX	2½" 4", 6" 100mm, 150mm	X	X
		Global Fire Sprinkler Corp.	Model F	2½", 4", 6"	X	X
		Star Sprinkler Corp.	Model A Model G	3", 6" 3", 6"	X	X
ASCO Solenoid Valve Model T8210A107 Model R8210A107 Model 8210A107 24VDC	1	The Viking Corp.	Model E-1	1½", 2", 3", 4", 6"	X	X
Sirai Solenoid Valve L182/ZB12A	1	Minimax	FSX-A	DN50, DN80, DN100, DN150, DN200	X	X

Solenoid Compatibility Data					
Manufacturer	Devices Per Circuit	Solenoid(s)	Voltage	PFC-4410RC	PFC-4410G3
ASCO	1	8210G227, X210509143001F1	24VDC	X	X
Burkert	1	5282	24 VDC	X	X
Parker	1	73212BN4TNLVN0C322C2, 73218BN4UNLVN0H111C2, or 7321GBN99NLVN0C322C2	24VDC	X	X
SIRAI	1	ZB12A	24 VDC	X	X
TLX	1	PA0036	24 VDC	X	X
Victaulic	1	753-E Series, 767 Series	24VDC	X	X
Viking	1	11591, 11601, 11602, 13843 or 13844	24VDC	X	X
FM Approval					
Solenoid Groups		4 (A, B, D, E, F, G, I, J, K, L)		X	X
Cease Fire Canister Automatic Release. Maximum 8 Per Release Circuit.				X	X
Agent Releasing Systems Compatibility Data					
Manufacturer	Actuator		Voltage		
Amerex	17014		24 VDC	X	X
Ceodeux Rotarex FireTec	B04425148		24 VDC	X	X
Ceodeux Rotarex FireTec	B04425149		24 VDC	X	X
Fike	UVO Model 02-13571		24 VDC	X	X
Fike Protection Systems Division of Fike, Inc.	C85-102 CO2 Solenoid		24 VDC	X	X
Fike Protection Systems Division of Fike, Inc.	Interface Firing Module P/N 10-2136*		24 VDC	X	X
Fike Protection Systems Division of Fike, Inc.	Direct Fired Impulse Actuator (DFIA) 2-13279		24 VDC	X	X
Fireaway	Stat-X Models 30E, 60E, 100E, 250E, 500E, 1000E, 1500E, and 2500E Aero-k Models G30, G60, G100, G250, G500, G1000, G1500, and G2500. Maximum 10 per release circuit, two release circuits max per panel.		24 VDC	X	X
FirePro	Model FP followed by a - number and letter suffix Maximum 10 per release circuit, two release circuits max per panel		24 VDC	X	X
Hochiki	Model FNX followed by a - number and letter suffix Maximum 10 per release circuit, two release circuits max per panel		24 VDC	X	X
Janus	FM200 Electric Valve Actuator P/N 18481		24 VDC	X	X
Masteco	MSC-01		24 VDC	X	X
Minimax	MX1230 and MX200 with Minimax actuator 887667 and 889323		24 VDC	X	
	MX1230 and MX200 with Minimax actuator 885738, 887667 and 889323 OXEO PR LCP with actuators 914027 and 925585 (EPU-1)		24 VDC		X
Viking	VSN1230 and VSN200 with actuator 887667 and 889323 VSH200 and VSH1230 with actuator 887667 and 889323		24 VDC	X	
	VSN1230 and VSN200 with actuator 885738, 887667 and 889323 VSH200 and VSH1230 with actuator 885738, 887667 and 889323 OXEO PR with actuators 914027 and 925585 (MZ-1)		24 VDC		X
TLX	PA0 128-7, PA0337		24 VDC	X	X
Alarm Indicating Appliance Compatibility Data					
All alarm indicating appliances must be UL Listed, 24 VDC devices					

\*\*\* FOR MORE INFORMATION REFER TO \*\*\*

**5403550 PFC-4410RC MANUAL**

**5403751 PFC-4410G3 MANUAL**