



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	6911-0328:0219
<b>PARENT LISTING No.:</b>	6912-1446:0100
<b>CATEGORY:</b>	6912 - VOICE COMMUNICATION ACCESSORIES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
<b>DESIGN:</b>	Models PVX 25, -25E, -50, -50E, -100, -100E, *-100M, -150, -150E, -200, -200E, -200M, -300, -300E, -400, -400E, -500, 500E, -600, -600E, *PVX-SC audio adjunct system. These units are intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	Input: 24-32 VAC/DC, Standby: 24 VDC, PVX 25 / 25E / 50/ 50E 7-18 Ah Battery  PVX -100, -100E, -100M, -150, -150E, -200, -200E, -200M, -300, -300E, -400, 400E, -500, 500E, -600, -600E 7-24 Ah Battery
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as a voice/tone communication/evacuation/relocation/audio adjunct system for use with separately listed electrically compatible fire alarm speakers and control units. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Suitable for high rise applications when used in conjunction with separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

\*Rev 10-29-19 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 07/03/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong** , Program Coordinator  
Fire Engineering & Investigations Division