



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0523
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Model Signalink Wireless Mesh System, consists of Model WTX-M Transmitter, Model WR Wireless Repeater, and Model WRX-R Wireless Receiver. The Wireless Mesh System is a primary battery system that can be used to create a wireless network. The transmitter connects to a dry contact type initiating device and the receiver provides a dry contact output to the FACP. Each receiver can only communicate with a single dedicated transmitter. Suitable for outdoor and damp environment.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
RATING:	<p>Model WTX-M: Input Voltage: 3.0VDC (Two Energizer Ultimate Lithium L91 Batteries, Size AA, 1.5V)</p> <p>Model WR: Input Voltage: 24VDC wired or 3.6VDC (One Xeno Energy XL-205F Battery, Size D, 3.6V)</p> <p>Model WRX-R: Input Voltage: 24VDC</p>
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 13, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and UL label.
APPROVAL:	Listed as control unit accessories for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

NOTES:

7-19-21 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division