

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7770-0328:0001
CATEGORY: 7770 -- VALVES/SWITCHES

Page 1 of 1

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Vane and pressure type water flow alarm switches listed below. Refer to listee's data sheet for detailed product description and operational considerations.

Vane Types:

VSR-CF	VSR-D	VSR-F	VSR-SF
VSR-FE-2	VS-SP	VS-F	VSR-SFG
VSR-SFT	VSG	VSR	VSR-S
VSR-C	VSR-ST	VSR-SG	

Pressure Type:

WFS-B	WFSR-C	WFSPD-B	PS10
PS-10A	PS-100A	WFSR-F	PS100

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL or FM label.

APPROVAL: Listed as waterflow alarm switches for use with fire sprinkler systems. Vane models may be used in wet pipe systems; pressure models may be used in wet or dry systems. Model VSR-CF is for use on K, L or M copper pipe (2", 2-1/2", 3", 4") and listed CPVC pipe (2", 2-1/2", 3"). Model VSR-SF for use on 1", 1-1/4", 1-1/2" and *2" steel, copper or listed plastic pipe. Model VSG is for low flow rate. Model VSR-SFG and VSR-SFT are for use on 1", 1-1/4", 1-1/2" and *2" plastic pipe. Models VS-F, VSR-F, VSR-FE and VSR-FE-2 is for use on 2", 2-1/2", 3", 3-1/2", 4", 5", 6", 8" and 10" pipe. *Model VSR is for use on steel pipe sizes from 2" through 8". Vane type switches may be used outdoors when the outdoor temperature never falls below 40oF.

Rev*5-17-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division