

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7770-0328:0010

Page 1 of 1

**CATEGORY:** 7770 -- VALVES/SWITCHES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Supervisory switches listed below to monitor pressure, OS&Y, gate, globe/gate, PIV, tank temperature or water level valves. Refer to listee's data sheet for detailed product description and operational considerations.

HLS-B	WLS-W	WLS-S	PS-40A
PS-120A	OSYSU-2	OSYS-B	PMS
PTS-B	OSYSU-1	GVS	PCVS-1
PIVS-B	TTS-S	TTS-W	PCVS-2
WLS	PTS-C	PS40	PS120
RBVS	*PS15	*PS25	

**INSTALLATION:** In accordance with listee's printed instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation and FM or UL label.

**APPROVAL:** Listed as sprinkler system supervisory switches.

**NOTE:** Formerly 7738-0328:010

\*Revision 09-07-2016 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*