

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7135-0328:0119

Page 1 of 1

**CATEGORY:** 7135 -- AUDIBLE DEVICES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Models SB624-153075, SB624-75110, PBA246, PBA248, PBA2410, PBA1206, PBA1208, PBA12010, \*PBD-126, \*PBD-128, \*PBD-1210, \*PBD-246, \*PBD-248, \* PBD-2410 vibrating bells. Suitable for outdoor use when used with Model BBK-1 backbox. Models are AC or DC powered and available in 6", 8" and 10". Models MBA-6, -8 and -10 bells, suitable for outdoor use when used with Model BBX-1 backbox. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** PBA-246, -248, -2410: 24 VAC  
PBA-1206, -1208, -12010: 120 VAC  
MBA-6, -8, -10: 12 or 24 VDC  
\*PBD-126, -128, -1210: 12VDC, .12A  
\*PBD-246, -248, -2410: 24VDC, .06A

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible fire alarm control units. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

\*Revision 01-31-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*