

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7120-0328:0145

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Model RA8F remote multiplex annunciator and RTI-1 Common trouble indicator. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model FA-200 Series fire alarm control unit (CSFM Listing No. 7165-0328:155).

XLF: 7120-1477:0108



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division