

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0328:0158

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: BillW@pottersignal.com

DESIGN: Models HP-25T, *MH120, *MH120R and *MH120W audible signal appliances. Intended for installation in a suitable single-gang electrical box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Model HP-25T 24 VDC
*Models MH120, MH120R and MH120W 120Vac

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as audible signal appliances for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

*Rev 07-08-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division