

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7125-0328:0186

**CATEGORY:** 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Models SL-1224, SL-1224-WP, CSL-1224-W strobes; SH-1224, SH-1224-WP, CSH-1224-W horn strobes. Models CSL-1224-W and CSH-1224-W employs amber, blue, green or red lens. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 12 or 24 VDC  
Selectable 15, 35, 60, 15/75, 75, 95 and 110 cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label. Models SL-1224-WP and SH-1224-WP are suitable for outdoor use when installed with Model BBX-5 backbox.

**APPROVAL:** Listed as Fire Alarm Devices for the Hearing Impaired for use with separately listed compatible fire alarm control units.

Unit can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:**

3-23-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*