# CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
# OFFICE OF THE STATE FIRE MARSHAL
# FIRE ENGINEERING & INVESTIGATIONS DIVISION
# BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

| | |
|---|---|
| **LISTING No.:** | 7300-0328:0192 |
| **CATEGORY:** | 7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES |
| **LISTEE:** | Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042<br>Contact: Decker, Tim (314) 595-6748<br>Email: timd@pottersignal.com |
| **DESIGN:** | Model RCDS-1 and Abort Switch. Both devices are accessories for releasing panels. |
| **RATING:** | 24 VDC, 2.5 Amps. |
| **INSTALLATION:** | In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Depending on applications, the authority having jurisdiction should be consulted prior to insulation. |
| **MARKING:** | Listee's name, model designation, electrical rating and UL label. |
| **APPROVAL:** | Listed as miscellaneous control accesssories for use with listee’s separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. |
| **NOTES:** | |

06-02-10 fm

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/09/2023**

**Listing Expires: 06/30/2024**

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division