CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7270-0328:0193 Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042

Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999

Email: billw@pottersignal.com

DESIGN: Models FHA and RHA heat detectors. Model FHA is a 135-185 °F fixed temperature heat

detector and Model RHA is combination 15 °F rate-of-rise and 135-174 °F fixed temperature heat detector. Unit consists of resistors, capacitors, diodes, transistors, LED, thermistors, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for

additional detailed product description and operational considerations.

RATING: FHA: 135-185 °F fixed temperature

RHA is combination 15 °F rate-of-rise and 135-174 °F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as heat detector for use with model AB-4, AB-6, AIB, ASB or ARB bases and

separately listed compatible fire alarm control units.

12-23-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2016 Listing Expires June 30, 2017

Authorized By: DAVID CASTILLO, Program Coordinator

Fire Engineering Division