

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0328:0204 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Model PFC-6006 fire alarm control panel. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer to listee's Installation Instruction Manual for details.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

07-25-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division