

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7135-0328:0217

Page 1 of 1

**CATEGORY:** 7135 -- AUDIBLE DEVICES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Model EH-24 horn and Models HS24-177 and HS-24 horn strobes. May be followed by -W (wall) and -W or -R (white or red) or -P plain. Models CHS-24 horn/strobe are ceiling mounted followed by -R (red), -W (white) or -P (plain). Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 24 VDC

Candela: 15cd, 15/75cd, 30cd, 60cd, 75cd, 110cd, 177cd.  
CHS-24 Ceiling: 15cd, 30cd, 75cd, 95cd 115cd (selectable)  
HS-24 Wall: 15cd, 30cd, 60cd, 75cd, 110cd (selectable)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as horn and horn/strobes for use with separately listed compatible fire alarm control units. For indoor use only. The audible in Models EH-24, HS24-177 and HS-24 may produce distinctive tones including: mechanical, 2400Hz and chime tones in continuous and temporal 3 settings as well as a whoop tone in either a high or low dBA setting .

Model CHS-24 may produce distinctive tones including mechanical and 2400Hz. Both models are capable of continuous and temporal 3 settings.

**XLF:** 7135-0569:0122

07-24-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*