

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0328:0221 Page 1 of 1

CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models *PVC-MP and *PVC-DP audio adjunct/voice evacuation systems. The *PVC-MP is the master panel in the system while the *PVC-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PWR-2A; Power Supply
MFP Master; Fire Phone Card
DCC ;Data Communication Control Card
ASC; Audio System Control Card
SSC; Switch Scan Card
MMC; Microphone Master Control Card
IOI; Input/Output Card
SLC; Switch and LED Card
MFH; Master Fire Phone Handset Card
MBR; Motherboard Card
AMI; Audio Module Interface Card
FPI; Motherboard/Relay Card
PVX's Models PVX-25, -25E, -50, -50E, -100 or -100E; Audio Adjunct Systems

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 6911-1446:0103

Revision10-26-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division