

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0328:0221
CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

Page 1 of 1

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models PVX-MP and PVX-DP audio adjunct/voice evacuation systems. The PVX-MP is the master panel in the system while the PVX-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

- PWR-2A; Power Supply
- MFP Master; Fire Phone Card
- DCC ;Data Communication Control Card
- ASC; Audio System Control Card
- SSC; Switch Scan Card
- MMC; Microphone Master Control Card
- IOI; Input/Output Card
- SLC; Switch and LED Card
- MFH; Master Fire Phone Handset Card
- MBR; Motherboard Card
- AMI; Audio Module Interface Card
- FPI; Motherboard/Relay Card
- PVX's Models PVX-25, -25E, -50, -50E, -100 or -100E; Audio Adjunct Systems

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 6911-1446:0103

08-06-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division