



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7135-0328:0521
PARENT LISTING No.:	7135-1683:0101
CATEGORY:	7135 - AUDIBLE DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Models PDC-612, PDC-812, PDC-1012, PDC-10G, *PAC-1206, *PAC-1208, and *PAC-12010 Fire Bells. Suitable for indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	*Models PDC-612, PDC-812, PDC-1012, and PDC-10G: 12 VDC *Models PAC-1206, PAC-1208, and PAC-12010: 120 VAC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical ratings, date of manufacture, Identify Marking: "Fire Alarm Service", and UL label.
APPROVAL:	Listed as audible devices for use with separately listed compatible fire alarm control units. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, the appliance must be used with a fire alarm control unit that can operate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.
NOTES:	

*Revision 9-8-22
 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/09/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong** , Program Coordinator
Fire Engineering & Investigations Division