

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7260-1508:0104 Page 1 of 1

**CATEGORY:** 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

**LISTEE:** FIRE FIGHTING ENTERPRISES LTD9 HUNTING GATE HITCHIN, HERTFORDSHIRE,  
England SG4 0TJ United Kingdom  
Contact: JACOB ANDELIN +44 (0)1462 444 740 Fax +44 (0)1462 444 789  
Email: jandelin@ffeuk.com

**DESIGN:** Model Fireray 5000 Projected Beam Smoke Detector. Units consist of a controller, reflector,  
and a combined transmitter/receiver. Refer to listee's data sheet for detailed product  
description and operational considerations.

**RATING:** 14 -\*36 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances  
and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as projected beam smoke detection systems for use with separately listed compatible  
fire alarm control units. Intended for mounting to vertical wall surfaces. Authority having  
jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction  
Manual for details.

\*Rev 02-02-16 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

*Listing Expires* **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
*Fire Engineering Division*