

## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No.:	7125-1517:0115
PARENT LISTING No.:	7125-0811:0130
CATEGORY:	7125 - FIRE ALARM DEVICES FOR THE HEARING IMPAIRED
LISTEE:	COMMERCIAL PRODUCTS GROUP (CPG) 1609 Park 370 Place, Hazelwood, MO, 63031 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Model FSEX, Series B1 strobe lights with clear lens. Refer to listee's data sheet for additional product description and operational considerations.
RATING:	Candela: 15 cd Electrical: 120/240 VAC, 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes, ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application (with clear lens only). Intended for use on wall or ceiling in non-sleeping areas. For indoor use only. Enclosure is rated NEMA or Type 4x.
NOTES:	

\*Rev. 06-23-2004



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test resultsand/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria.Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/10/2023

Listing Expires: 06/30/2024



## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

Authorized By: Victor Wong , Program Coordinator Fire Engineering & Investigations Division