



Service Pressure: Up to 175 PSIG

Temperature Range: Up to 120°F (4.5°C to 49°C)

Purge Valve: 1/2" NPT inlet
Brass Construction

Ordering Information:

Stock No.	Model/Description
1119784	NGP-SPV - Potter Nitrogen Self Purge Valve

General Description

The Potter Nitrogen Self Purge valve (NGP-SPV) is designed to work with Potter Nitrogen Generators Systems to effectively purge corrosive oxygen from a fire sprinkler system while maintaining adequate system pressure. Potter's Self Purge Valve is the easiest way to ensure high purity nitrogen is equally distributed throughout the fire sprinkler system. Simply install the NGP-SPV off a tee connection at the end of the sprinkler system. No electrical connections are required. When the nitrogen generator is in operation the purge orifice automatically bleeds out the oxygen as well as the residual moisture in the system. The purge valve also provides a sampling port to monitor the nitrogen purity within the system piping.

In the event of an alarm condition the NGP-SPV has a built in high pressure water shut-off valve that automatically closes when the water reaches the vent. A plug is supplied to keep the purge orifice free of debris when not in use. A ball valve allows for isolation of the assembly, maintenance of strainer screen, replacement of air vent, or maintenance of the purge orifice.

Installation and Servicing (See Figures 1 & 2)

1. Read and understand the instructions provided before proceeding with installation. The NGP-SPV shall be installed in accordance with local ordinances and the applicable NFPA 13, NFPA 13D, or NFPA 13R standard.
2. The Engineer of Record should select the Model NGP-SPV, Potter Nitrogen Self Purge Valve installation location. This is usually located at the end point of the system.

3. The location of the NGP-SPV must not interfere with the spray pattern of any sprinkler head.

CAUTION

NGP-SPV valves must be installed in a level horizontal position.
See Figure 2.

4. The piping must be level and arranged in such a manner that water will not become trapped. Trapped water could cause the NGP-SPV not to purge.
5. Using the union, position the purge orifice (N₂ sampling part) for easy access.
6. After installation, close ball valve prior to initiating test or purging process.
7. Purging process operation instructions are located in the Potter Nitrogen Generator Manual.
8. The unit should be inspected periodically. Thereafter, the manufacturer recommends quarterly or more frequently inspections.
9. Inspection should include removal and cleaning of the strainer screen. Remove the screen and flush with clean water. Use a wire brush if necessary to remove any particles trapped in the screen.
10. Plug should be installed in orifice when purging process is not being performed to keep orifice free of debris and buildup.

Fig. 1 NGP-SPV Assembly





Fig. 2 NGP-SPV Installation Diagram



DWG. #0400-13

NGP-SPV shown installed horizontal and level.