CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7770-0328:0141
CATEGORY:	7770 - VALVES/SWITCHES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Models PS10-EX and PS40-EX pressure operated switches. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	10A, 125-250 VAC; 2.5A, 0-30 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating and UL label.
APPROVAL:	Listed as pressure switches for use with fire sprinkler systems. Suitable for use in hazardous locations, Class I, Group B, C and D; Class II, Group E, F and G.
NOTES:	

*Rev 6-20-2002

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/26/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division