



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7150-0328:0156
PARENT LISTING No.:	7150-1039:0101
CATEGORY:	7150 - FIRE ALARM PULL BOXES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Models P32-1T (allen or key, no push bar) and P32-1T-LP (key lock or allen key) noncoded manual pull stations. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	10 Amp. @ 120 VAC, 30VDC
INSTALLATION:	In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as manual pull stations for use with separately listed and compatible fire alarm control units. These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments.
NOTES:	

*Rev 8-3-2009 fm



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division