



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7610-0328:0185
<b>CATEGORY:</b>	7610 - MISC. ACCESSORIES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
<b>DESIGN:</b>	Model QRS and EDPA Accelerator System for Dry Pipe Valves. System consists of a Potter Model QRS Quick Release Pressure Switch, Potter Model PFC-4410-RC Fire Alarm Releasing Panel, Skinner Model 73218BN4UNLVNOC111C2 solenoid valve and trim. Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	120 VAC 165VA - 60Hz  220 VAC 185VA - 50-80Hz
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating and FM label.
<b>APPROVAL:</b>	Listed as an accelerator for compatible dry pipe and preaction valves. Refer to manufacturer's Installation Manual for Details.
<b>NOTES:</b>	

06-01-10 fm



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/27/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division