

## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No.:	7270-0328:0193
CATEGORY:	7270 - HEAT DETECTOR
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Models FHA and RHA heat detectors. Model FHA is a 135-185 °F fixed temperature heat detector and Model RHA is combination 15 °F rate-of-rise and 135-174 °F fixed temperature heat detector. Unit consists of resistors, capacitors, diodes, transistors, LED, thermistors, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	FHA: 135-185 °F fixed temperature RHA is combination 15 °F rate-of-rise and 135-174 °F fixed temperature
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model designation, rating and UL label.
APPROVAL:	Listed as heat detector for use with model AB-4, AB-6, AIB, ASB or ARB bases and separately listed compatible fire alarm control units.
NOTES:	

12-23-10 bh



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

## Date Issued: 05/03/2024

Authorized By: **David Castillo**, Program Coordinator Fire Engineering & Investigations Division Listing Expires: 06/30/2025