



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7272-0328:0194
CATEGORY:	7272 - SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Models PSA and PSHA photoelectric type smoke detectors. Model PSHA employs a supplemental heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	22-24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model designation, electrical rating and UL label.
APPROVAL:	Listed as photoelectric smoke detectors for use with separately listed compatible fire alarm control units when used in conjunction with listee's Models AB-4, AB-6, ASB, AIB and ARB bases. Models with supplemental heat sensor are not approved for use in lieu of the required heat detectors.
NOTES:	

12-23-10 bh



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division