

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0328:0196

Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Bill Witherspoon (314) 595-6731 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models PFC- 8060, PFC-8060/230, PFC-8500 and PFC-8500/230 fire alarm control units. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer to listee's Installation Instruction Manual for details. System components:

PFC-8000: Power Supply
ALE-127: Loop Expander Board
3005013, 3005012: EOL Resistors
LCD-AN, LED-AN: Remote Annunciators
CIZM-4: Smoke Detector Module
SCI: Loop Powered Short Circuit Isolator
MCM: Miniature Contact Module
SCM-4, DCM-4: Loop Powered Contact Modules
TRM-4: Twin Relay Module
MOM-4: Monitor Output Module

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

Units meet the requirements of UL Standard 864, 9th edition.

04-11-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division