

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 6912-0328:0197 Page 1 of 1

**CATEGORY:** 6912 -- VOICE COMMUNICATION ACCESSORIES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Model VAB-802 Audio Booster with an AX-PSU-6 power supply/charger, AV-AMP-80 audio amplifier module, and an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

Model PVE-802 Audio Panel w/microphone with an AX-PSU-6 power supply/charger, AV-AMP-80 audio amplifier module, microphone, switch/ED module (AV-SM), and an enclosure. It can provide live voice communication override. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 120-240 VAC, 3A, 50/60Hz

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and ETL label.

**APPROVAL:** Listed for use with separately listed fire alarm control panel to provide audio signaling during an emergency situation (alarm, alerts, warnings, mass notification, etc.). Refer to listee's Installation Instruction Manual for details.

**XLf:** 6912-1713:0117

10-31-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*