

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-0328:0198 Page 1 of 1

**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO 63042 United States  
Contact: Bill Witherspoon (314) 595-6731 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Models PFC-6500, PFC-6500R, P400, \*P400R and PFC-6800 fire alarm control panels  
Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary,  
releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer  
to listee's Installation Instruction Manual for details. System components:

CA-6500: Class A Expander  
UD-1000: DACT  
\*3006607, \*3006610, \*3006623, \*3006623, \*3006618 : Main Boards  
RA-6075, RA-6075R, RA-6500: Remote Annunciators  
3005013, 3005012: EOL Resistors  
PSN-1000, PSN-1000(E): Fire Power Expander  
Models AE-8, AE-14; Power expander enclosures  
SLCE-127: Loop Expander

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances  
and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, rating and UL label.

**APPROVAL:** Listed as fire alarm control units when use with separately listed electrically and functionally  
compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual  
for details.

**NOTE:** For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum  
Retard/Reset/Restart period shall not exceed 30 seconds.

\*Rev 02-08-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*