

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0328:0198 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models PFC-6500, PFC-6500R, P400, *P400R and PFC-6800 fire alarm control panels
Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary,
releasing, remote station (PPU), proprietary (PPU) and central station (PPU) services. Refer
to listee's Installation Instruction Manual for details. System components:

CA-6500: Class A Expander
UD-1000: DACT
*3006607, *3006610, *3006623, *3006623, *3006618 : Main Boards
RA-6075, RA-6075R, RA-6500: Remote Annunciators
3005013, 3005012: EOL Resistors
PSN-1000, PSN-1000(E): Fire Power Expander
Models AE-8, AE-14; Power expander enclosures
SLCE-127: Loop Expander

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fire alarm control units when use with separately listed electrically and functionally
compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual
for details.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum
Retard/Reset/Restart period shall not exceed 30 seconds.

*Rev 02-08-16 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division