

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0328:0201

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models APS-SA, *PAD100-PSSA single action and APS-DA, *PAD100-PSDA dual action addressable pull boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 22-24 VDC

INSTALLATION: In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed addressable pull boxes for use with separately listed and compatible fire alarm control units. For indoor use only. Refer to listee's Installation Instruction Manual for details.

NOTE: These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments.

*Revision 02-10-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division