



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7320-0328:0208
PARENT LISTING No.:	7320-0569:0137
CATEGORY:	7320 - SPEAKERS
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Model FASPKR ceiling and wall mounted speaker. Model SPKSTR-24CLP ceiling mounted speaker strobe. Models FASPKR and SPKSTR-24CLP are available in red or white. Models are to be mounted in standard 4" X 2 1/8 " back boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	Speaker 25 Vrms and 70.7 Vrms Strobe 21-30 VDC Flash Rate 60 flashes per minute Candela 15, 30, 75, 95 and 115 cd
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical/candela ratings and UL label.
APPROVAL:	Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Units with strobe lights are suitable for the hearing impaired applications. For indoor use only.
NOTES:	

07-24-13 gt





**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/26/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division