

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7135-0328:0210

Page 1 of 1

**CATEGORY:** 7135 -- AUDIBLE DEVICES

**LISTEE:** Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Model CHS-24A, CHS-24B, CHS-24G and CHS-24R horn/strobe lights. Units employ a strobe flash tube and electronic trigger circuit mounted on a printed wiring board with color lens. Unit is intended for indoor or outdoor use when mounted on the wall only. When used outdoors either Model WPBB weatherproof enclosure or Model WPLPBB low profile weatherproof enclosure must be employed. Unit is for private mode signaling use only. Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 16 - 33 VDC

Candela: 15cd, 30cd, 60cd, 75cd and 110cd Selectable

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as horn/strobes for use with separately listed compatible fire alarm control units. Not approved for hearing impaired applications.

**XLF:** 7135-0569:0135

07-24-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*