



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7125-0328:0216
PARENT LISTING No.:	7125-0569:0123
CATEGORY:	7125 - FIRE ALARM DEVICES FOR THE HEARING IMPAIRED
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Models S24-177 and *S-24 strobe lights followed by suffix -W (wall mount), followed by -W or -R (white or red). Intended for indoor use and wall mount only. Model AVSM Sync Module intended for indoor use with Potter Electric Signal Company synchronizable strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	<p><u>Candela:</u> *15cd, 15cd & 75cd at 00 angle axis</p> <p style="padding-left: 100px;">30cd, 60cd, 75cd, 110cd, 177cd.</p> <p style="padding-left: 100px;">*Model S-24: Selectable 15cd, 30cd, 60cd, 75cd and 110cd.</p> <p><u>Electrical:</u> 21-30 VDC</p> <p style="padding-left: 100px;">Model AVSM: 8-33 VDC/VFWR</p> <p><u>Flash Rate:</u> 60 flashes per minute</p>
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical and candela ratings and UL label.
APPROVAL:	Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

*Revision 05-01-20 VWW



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/03/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division