

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0328:0216 Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, 63042 United States
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: Models S24-177, and S-24 strobe lights; followed by suffix -W (wall mount), followed by -W or -R (white or red). Intended for indoor use and wall mount only. Model AVSM Sync Module intended for indoor use with Potter Electric Signal Company synchronizable strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: 15cd, 15cd & 75cd at 00 angle axis
30cd, 60cd, 75cd, 110cd, 177cd.
Model S-24: Selectable 15cd, 30cd, 60cd, 75cd and 110cd
Electrical: 21-30 VDC
Model AVSM: 8-33 VDC/VFWR
Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical and candela ratings and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units.

XLF: 7125-0569:0123

08-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division