

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0328:0217

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Michael Mclsaac (314) 628-2218 Fax (314) 595-6999
Email: michaelm@pottersignal.com

DESIGN: Model EH-24 horn and Models HS24-177 and HS-24 horn strobes. May be followed by -W (wall) and -W or -R (white or red) or -P plain or *LP low profile. Models CHS-24 horn/strobe are ceiling mounted followed by -R (red), -W (white) or -P (plain). Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 24 VDC

Candela: 15cd, 15/75cd, 30cd, 60cd, 75cd, 110cd, 177cd.
CHS-24 Ceiling: 15cd, 30cd, 75cd, 95cd 115cd (selectable)
HS-24 Wall: 15cd, 30cd, 60cd, 75cd, 110cd (selectable)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as horn and horn/strobes for use with separately listed compatible fire alarm control units. For indoor use only. The audible in Models EH-24, HS24-177 and HS-24 may produce distinctive tones including: mechanical, 2400Hz and chime tones in continuous and temporal 3 settings as well as a whoop tone in either a high or low dBA setting. *May be used outdoors when used with Model GOE or GOELP (CSFM Listing No. 7300-0569-124).

Model CHS-24 may produce distinctive tones including mechanical and 2400Hz. Both models are capable of continuous and temporal 3 settings.

XLF: 7135-0569:0122

*Rev 07-08-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division