



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	6912-0328:0220
<b>PARENT LISTING No.:</b>	6912-1446:0101
<b>CATEGORY:</b>	6912 - VOICE COMMUNICATION ACCESSORIES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
<b>DESIGN:</b>	Model PVX-4Z zone splitter.. The unit is intended to be used in conjunction with a listee's separately listed Model PVX-25, PVX-50, PVX-100, PVX-150 and PVX-200 audio adjunct system (CSFM Listing No. 6911-0328:0219). Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	Input: 24-28 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating and UL label.
<b>APPROVAL:</b>	Listed as a voice communication/audio adjunct system accessories.
<b>NOTES:</b>	

08-06-13 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 07/26/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo** , Program Coordinator  
Fire Engineering & Investigations Division