



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7125-0328:0222
<b>PARENT LISTING No.:</b>	7125-0569:0123
<b>CATEGORY:</b>	7125 - FIRE ALARM DEVICES FOR THE HEARING IMPAIRED
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
<b>DESIGN:</b>	Model CS-24 strobe light; followed by W or R (white or red color) and P (plain). For indoor use on wall or ceiling mount. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	<u>Candela:</u> Selectable 15cd, 30cd, 75cd, 95cd and 115cd  <u>Electrical:</u> 21-30 VDC  <u>Flash Rate:</u> 60 flashes per minute
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical and candela ratings and UL label.
<b>APPROVAL:</b>	Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

01-06-14 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 07/26/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo** , Program Coordinator  
Fire Engineering & Investigations Division