

## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No.:	7135-0328:0227
PARENT LISTING No.:	7135-0569:0148
CATEGORY:	7135 - AUDIBLE DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Model LFH-24 low frequency horn. The model may be followed by a letter indicating product color. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	16-33 Vdc/VFWR
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as a low frequency horn when used with a separately listed electrically compatible fire alarm control unit. For indoor use only. Suitable for wall or ceiling mount. This unit can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to listee's Installation Instructions Manual for details.
NOTES:	

10-01-15 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test resultsand/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria.Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/19/2025

Listing Expires: 06/30/2026



## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

Authorized By: **Michael Huang**, Program Coordinator Fire Engineering & Investigations Division