



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7270-0328:0503
CATEGORY:	7270 - HEAT DETECTOR
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Model PAD100-HD heat detector head. Model PAD100-HD is a combination 15°F rate-of-rise and 135°-174°F fixed temperature heat detector head. Refer to Listee's data sheet for detailed product description and operational considerations.
RATING:	24 Vdc
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as a heat detector head for use with listee's detector base Models PAD100-4DB, PAD100-6DB, PAD100-RB, PAD100-SB (CSFM#7300-0328:502) and Model PAD100-IB (CSFM#7300-0328:501). Refer to listee's Installation Instruction Manual for details.
NOTES:	

06-21-2017 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division