CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	5278-0328:0506
CATEGORY:	5278 - CARBON MONOXIDE DETECTORS
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Model PAD100-CD carbon monoxide detector head. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	24 Vdc
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, UL labeling, electrical rating, and required WARNINGS label.
APPROVAL:	Listed as a carbon monoxide head for use with listee's detector base Models PAD100-4DB, PAD100-6DB, PAD100-RB, PAD100-SB (CSFM#7300-0328:502) and Model PAD100-IB (CSFM#7300-0328:501).
NOTES:	Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

06-21-2017 dcc

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/02/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division